



Development Services

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 06.20.2013

TO: ProTrack

FROM: Bill McDow
Transportation Planning

Dave Brent
Traffic Engineering

■ **JERVAY HOUSE II [plan review #4]**

TECHNICAL STANDARDS – Parking

1. Parking spaces must be at least 18' in length. If overhang is used, the parking space must be at least 15.5' in length to the face of curb. Current spaces are shown as 15'. Show change on the final plan.
2. No further comments at this time.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.