



**Planning, Development
and Transportation**
Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 6.27.2018

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **REED'S PARKING FACILITY [TRC Plan Review #2]**

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

1. As previously stated the sidewalk ends prior to the end of the last handicap parking space. Please extend the sidewalk connection to the end of the handicap parking spaces.

TECHNICAL STANDARDS – PARKING:

2. Graphically indicate on the plans the location of bike parking. [[Sec.18-528 CofW LDC](#)]
3. No Further Comments.