



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
Dial 711 TTY/Voice

**DATE:** 07.02.2018

**TO:** ProTrak

**FROM:** Mitesh Baxi  
Traffic Engineering

---

■ **JORDAN LANE DUPLEXES [TRC Plan Review #2]**

**TECHNICAL STANDARDS – PARKING:**

- 'No parking' sign must be installed in the middle of the backing stub, at the 5' sidewalk edge abutting the ROW pavement, restricting the vehicle overhang on the sidewalk.

**GENERAL NOTES TO ADD TO THE PLAN:**

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.