

**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC
28402-1810

DATE: 7.06.2017

TO: ProTrak

910 341-3258
910 341-7801 fax

FROM: Bill McDow,
Transportation Planning



NHRMC EMPLOYEE PARKING DECK PEDESTRIAN BRIDGE [TRC Plan Review #4]

TECHNICAL STANDARDS:

1. Ensure proposed street trees for the driveways have clear sight distance from 30" to 10'. Currently, trees are shown in the sight distance triangle.
2. No Further Comments.

