



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

**DATE:** 07.09.2018  
**TO:** ProTrak  
**FROM:** Mitesh Baxi  
Traffic Engineering

910 341-3258  
910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
Dial 711 TTY/Voice

---

■ **DOLLAR GENERAL PINE GROVE [TRC Plan Review #2]**

**TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):**

1. Please revise to show the 'STOP' sign aligning stop bar at the driveway for this project. [MUTCD]

**TECHNICAL STANDARDS – Barrier Free Design:**

2. Accessible parking signs shall be relocated to allow 2.5' of vehicle overhang and avoid sign damage. Or install the wheel stops for handicap spaces.
3. Please note that if these signs are relocated, it must leave sidewalk clear.

**MISCELLANEOUS:**

- ❖ We will reserve comments on the parking lot, driveway geometry and other technical issues until a full construction drawing is submitted.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.