



**Planning, Development
and Transportation**
Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 07.10.2015

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **SEAGATE LANDING [TRC Plan Review #2]**



TECHNICAL STANDARDS:

1. Please coordinate with City Stormwater Department the drainage plan for White Ave. Ensure the proposed header curb will allow adequate drainage in the area between the 16' roadway and sidewalk without negatively impacting adjacent properties.
2. Please show any proposed street trees, street lights or landscaping planned for this subdivision on the site plans.
3. No Further Comments.

MISCELLANEOUS:

- ❖ Include appropriate City of Wilmington approval stamps prior to submitting final plans.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.