



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 07.30.2015

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **HOGGARD BASEBALL FACILITY BLDG UPGRADE [TRC Plan Review# 2]**

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

1. Ensure area at rear of concessions area maintains a 12' to 14' clear fire lane for vehicle access to the rear of concession stands and the buildings near the softball field.
2. No Further Comments.