

Engineering has reviewed the plans for the NHRMC Wound Care Facility project submitted July 19, 2017 and have the following comments:

1. This project is proposing the construction of on-site newly constructed impervious surface greater than 2,500 sf but less than 10,000 sf, therefore the project is subject to a Drainage Plan review. Please see the Drainage Plan Requirements found on the city website. A complete Drainage Plan submittal is required and consists of a fully executed Stormwater Management Permit Application Form, a \$200 permit application processing fee, one full set of design plans and a digital copy of the entire submittal package. Additional comments will be made once the full engineering submittal is reviewed. Please note our review times for Drainage Plans are approximately 15-30 days. Please factor this into your submittal schedule.
2. Please verify that there are no existing State Stormwater permits for this site.

Call or email if you have any questions.