



DATE: 08.06.2018

TO: ProTrak


FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **RENAISSANCE II BUILDING [LANDSCAPE Plan Review #5]**

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

1. Please reposition the trees away from the blocking sight distance at the cross walks, or at the 'ingress side' of the Roundabout. The Willow Oak located beside the southern crosswalk and northern crosswalk locations may block clear visual sight lines for vehicles approaching the crosswalks. [[Sec.18-566 CofW LDC](#)]
2. Please ensure proposed landscaping located in Sight Distance Triangles are positioned or trimmed to provide clear visual sight lines from 30" to 10'. [[Sec.18-566 CofW LDC](#)] The proposed landscape plan show Willow Oaks (Street Trees) around the proposed Roundabout on Fresco Drive and adjacent to marked crosswalks.
3. Show and apply the City's 46'x46' sight distance triangle at each street corner intersection (with the Roundabout), at Fresco Drive and Ashes Drive on the site plan and landscaping plan. [[Sec.18-529\(c\)\(3\)CofW LDC](#)] Add a note indicating that all proposed vegetation within sight triangles shall not interfere with clear visual sight lines from 30"-10'.



Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.