



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 08.08.2018

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **RENAISSANCE II BUILDING [LANDSCAPE Plan Review #6]**

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

1. The Hornbeam Tress located at the Southern end of the Roundabout appears to be too close to the crosswalk. Please reposition the trees away from the cross walk, in order to prevent it from blocking sight distance at the cross walk.
2. No Further Comments.