



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 08.14.2015

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **RIVERLIGHTS AGE QUALIFIED Construction- PHASE 1 [Plan Review #3]**

1. Ensure the proposed crosswalk at the entrance to the project, (River Road and Passerine Avenue intersection) has a standard 10' crosswalk for the 10' multi-use path connection. The concrete traffic islands appear to be encroaching the crosswalk/multi-use path.
2. Contact Alina Jakubcanin at (910) 341-7893 to discuss street lighting type and spacing.
3. No Further Comments.