



**Planning, Development  
and Transportation**  
Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

**DATE:** 08.20.2018

**TO:** ProTrak

**FROM:** Bill McDow  
Transportation Planning

910 341-3258  
910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
Dial 711 TTY/Voice

---

■ **WILMINGTON PAWVILLE [TRC Plan Review #3]**

**TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):**

1. As previously stated, the 20'X70' Sight Distance Triangle appears to have 2 objects within this area, a business sign and a CFPUA backflow preventer. Please ensure the backflow preventer and business do not hinder clear visual sight distance from 30" to 10' sign within the sight distance triangle.

**TECHNICAL STANDARDS – PARKING:**

2. Please provide a landscape plan or show proposed landscaping on this plan.
3. No Further Comments.