



**Planning, Development  
and Transportation**  
Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

**DATE:** 08.29.2018  
**TO:** ProTrak  
**FROM:** Mitesh Baxi  
Traffic Engineering

910 341-3258  
910 341-7801 fax  
www.wilmingtonnc.gov  
Dial 711 TTY/Voice

---

■ **WILMINGTON PAWVILLE [TRC Plan Review #3]**

**TECHNICAL STANDARDS – ACCESS (driveway, sidewalk):**

1. Show proposed driveway centerline elevations and sectional details at both the front and the back of concrete driveway apron, at the curb line, property line & points at 26' and 52' behind the property line. [[Chapter VII, C \(1\) \(a\) \(2\)12 CofWTSSM](#)].

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.