



**Planning, Development
and Transportation**
Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 08.31.2015
TO: ProTrak
FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **DECKS AND DOCKS LUMBER COMPANY [TRC Plan Review #2]**



TECHNICAL STANDARDS – PARKING AND SIGHT DISTANCE:

1. The proposed street trees appear to be within the sight distance triangles. How will clear vertical sight distance from 30" to 10' within the sight distance triangles be maintained?
2. Please show the location of the proposed bicycle parking which was proposed in the site development data. [[Sec.18-528 CofW LDC](#)]

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.