



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 09.01.2015

TO: ProTrak

FROM: Bill McDow
Transportation Planning

■ **AIRLIE OFFICES [Landscape Plan Review]**

TECHNICAL STANDARDS –

1. The fire hydrant located in central island on the northern side of the parking lot, (between the building and the infiltration basin), appears to be obscured by landscaping.
2. Provide the required 3' circumference of clearance around the fire hydrant within this island.
3. No Further Comments.