



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 09.10.2018

TO: ProTrak

FROM: Mitesh Baxi
Traffic Engineering

■ **NEEDHAM ANIMAL HOSPITAL EXPANSION [TRC Plan Review #3]**

TECHNICAL STANDARDS – PARKING:

1. Site plan is missing International symbol of Accessibility parking space marking for couple of the handicap spaces [fig. 3B-22 of MUTCD]. Or revise the number of handicap spaces in the site development data.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.