



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 09.16.2014

TO: ProTrak

FROM: Bill McDow
Transportation Planning

■ **THE SOLSTICE LOFTS AT RANDALL PARKWAY [Plan Review# 3]**

1. Lighting levels at the sides and rear of buildings, especially in the passive recreation areas are near zero foot candles. These conditions are also present at the north side and east side of the office building. Please consider adjusting the lighting level in these areas and at the connections to 10' Multi-use Path from buildings 1-3.
2. The seven (7) parking spaces on the East side of Building 2 do not have sidewalk adjacent to these spaces. Please consider adding sidewalk in front of these spaces.
2. No Further Comments.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.