



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
www.wilmingtonnc.gov  
Dial 711 TTY/Voice

**DATE:** 9.19.2019

**TO:** ProTrak

**FROM:** Bill McDow  
Transportation Planning

---

■ **MAYFAIRE SELF DEVELOPMENT [TRC Plan Review #2]**

**TECHNICAL STANDARDS – PARKING:**

1. The minimum radius is 25' for any portion of a parking lot adjacent to a travel way (i.e. islands at the end of a parking bay) for parking that is open to the public. If the travel way will not be used for emergency service vehicles or truck traffic, you may request a tighter radius, the minimum is 15'. This request must be made in writing. [[Chapter VII, Detail SD 15-13 CofWTSSM](#)]
2. No Further Comments.