



**DATE:** 09.26.2019  
**TO:** ProTrak  
**FROM:** Bill McDow  
Transportation Planning

910 341-3258  
910 341-7801 fax  
www.wilmingtonnc.gov  
Dial 711 TTY/Voice

■ **INDIE ICE HOUSE LOFTS [TRC Plan Review]**



🔗 Initial Review Note 🔗

All comments are based on adopted policy documents, specific City of Wilmington Land Development Code (CofW LDC) and City of Wilmington Technical Standards and Specifications Manual (CofWTSSM) requirements in effect at the time of this review. These have been noted after the comment as appropriate for your ease in further research.

The City Engineer may administratively approve dimensional variance requests per LDC Sec. 18-348. If the Applicant feels further interpretation is in order, please contact Transportation Planning directly to discuss in additional detail. Please apply for all administrative variances in writing, an email is acceptable or this may be included on the plan set. Please see Sec. 18-348 of the Land Development Code for the information required to process a variance request.

**TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):**

1. The proposed Sight Distance Triangle is shown on a parking space and not a driveway or street. Please show and apply the City's 20'x70' sight distance triangle at each driveway and the City's 46'x46' sight distance triangle at each street corner intersection on the site plan and landscaping plan. [Sec.18-529(c)(3)CofW LDC] Add a note indicating that all proposed vegetation within sight triangles shall not interfere with clear visual sight lines from 30"-10'. [Sec.18-566 CofW LDC]



**TECHNICAL STANDARDS – PARKING:**

2. As the developer has chosen to provide automobile spaces, please provide bicycle parking in on the site. Please add the required number and the proposed number to the site data table and graphically indicate on the plans the location of bike parking. [Sec.18-528 CofW LDC]

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.