



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
Dial 711 TTY/Voice

**DATE:** 10.16.2018

**TO:** ProTrak

**FROM:** Mitesh Baxi  
Traffic Engineering

---

■ **WILMINGTON MUNICIPAL GOLF COURSE [TRC Plan Review #2]**

**TECHNICAL STANDARDS – PARKING:**

1. Site proposes 5 parking spaces for staff, beside the proposed maintenance addition. Dimension these parking spaces and drive aisle.

**TECHNICAL STANDARDS – Barrier Free Design:**

2. Site plan shows striped crosswalks at various locations but it is not clear whether ramps are provided on both the sides of the crosswalks. Please verify and revise to show/label ramps on both the sides of crosswalk. Connect the ramps to the sidewalk in accordance with City and ADA standards.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.