



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 10.23.2018

TO: ProTrak

FROM: Bill McDow
Transportation Planning

■ **CALIBRATION STATION OFFICES [TRC Plan Review #3]**

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

1. The sidewalk modification to the sidewalk near the 36" Oak Tree appears to be creating nonstandard wheel chair ramps. Please redesign the corner to meet city technical standards for intersection and wheel chair ramp design. [[Standard Details SD 3-08 and SD 3-09, CofW TSSM](#)]
2. Provide a pedestrian crossing sign and pavement markings for the crossing at Southern Blvd and Virginia Avenue.
3. No Further Comments.