



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 10.24.2017

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **TONGUE AND GROOVE OFFICE [TRC Plan Review# 11]**

TECHNICAL STANDARDS – DRIVEWAY ACCESS:

1. The sidewalk for the proposed driveway on Circular Drive is shown on the landscape plan but not on the site plan. Has this requirement been removed by Planning?

TECHNICAL STANDARDS – PARKING:

2. Please ensure the perpendicular parking spaces have 24' behind them.
3. Show the location of the business sign.