



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
www.wilmingtonnc.gov  
Dial 711 TTY/Voice

**DATE:** 10.24.2018  
**TO:** ProTrak  
**FROM:** Mitesh Baxi  
Traffic Engineering

---

■ **KIDDIE ACADEMY [TRC Plan Review #2]**

**TECHNICAL STANDARDS – Driveway:**

1. Location of the dumpster shall be revised to ensure that ingress and egress of the dumpster truck is by forward motion only. [Sec.18-526 CofW LDC] Provide the auto-turn of the dumpster truck ensuring no backing into the existing sidewalk.
2. The gate of dumpster must not block the drive aisle. Please revise.

**TECHNICAL STANDARDS – Barrier Free Design:**

3. Handicap Sign Detail on details sheet is incorrect. Where a van accessible parking is provided, van accessible sign shall be mounted below the other accessible parking signs.
4. Show the typical handicap sign detail on the plan as per ADA and City standards. [Sheets A1 of 5 and A2 of 5, CofW Sign Specification]  
<https://www.wilmingtonnc.gov/home/showdocument?id=3940>

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.