



**Planning, Development
and Transportation**
Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 10.24.2019

TO: ProTrak

FROM: Bill McDow
Transportation Planning

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **TRIANGLE AUTO SALES [TRC Plan Review #2]**

TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):

1. As previously stated, provide a sidewalk connection between the site and the public sidewalk
2. Thank you for providing the landscape plan.

TECHNICAL STANDARDS – PARKING:

3. As previously stated, please provide a turning movement analysis of an auto hauler vehicle at this location. Please show whether the auto hauler is an 8 or 10 vehicle hauler.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.