



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
Dial 711 TTY/Voice

**DATE:** 10.29.2019

**TO:** ProTrak

**FROM:** Bill McDow  
Transportation Planning

---

■ **THE MINI PEARL [TRC Plan Review #4]**

**TECHNICAL STANDARDS – ACCESS (driveway, sidewalk, and sight distance):**

1. The proposed landscape plan does not match the site plan for the project. Please revise to meet the site plans.
2. The site has a proposed sidewalk connection to Wooster Street. Please ensure the sidewalk connection shown on the site plans match the sidewalk connection on the landscape plan.

**TECHNICAL STANDARDS –BARRIER FREE DESIGN:**

3. The landscape plans do not show the handicap parking space and handicap accessible aisle shown on the site plan for the project. Please revise to meet the site plans.
4. Please show the handicap ramps shown on the site plan.
5. No Further Comments.