



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
Dial 711 TTY/Voice

**DATE:** 11.28.2017

**TO:** ProTrak

**FROM:** Bill McDow  
Transportation Planning

---

■ **LOU'S FLOWERS [Plan Review #5]**

**TECHNICAL STANDARDS – PARKING:**

1. The loading zone spaces do not have dimensions. Please ensure they are a minimum of 12'X25'.
2. Add dimensions for the angled parking spaces. Minimum size for 45 degree parking is 8.5'X19'.
3. As mentioned in previous submissions, please add "Do Not Enter Sign" for the one way area that is near the dumpster enclosure and angled parking spaces.
4. No Further Comments.