



Development Services
Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 12.05.2012

TO: ProTrack

FROM: Tara S. Murphy, ASLA/RLA/LEED AP
Transportation Planning

Dave Brent
Traffic Engineering

■ **NEW CENTER TSP [2nd Review]**

TECHNICAL STANDARDS:

1. Provide curb and gutter detail (SD 7-01)
2. Provide all (four) centerline driveway elevations (front and back of apron and 26' & 52' behind the apron) at each driveway.
3. Sight distance triangles to be drawn at the face of curb. Please adjust.

