



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
Dial 711 TTY/Voice

**DATE:** 12.05.2019

**TO:** ProTrak

**FROM:** Mitesh Baxi  
Traffic Engineering

---

■ **MARSHES AT RIVER'S EDGE PHASES 3, 4, 5 [TRC Plan Review #3]**

**TECHNICAL STANDARDS – PARKING:**

1. The backing stub at the northern most parking facility of phase 5 is shown as 5' deep. The backing stub is to be 10' deep by 15' wide. Please revise or coordinate with Engineering for a variance. [[Chapter VII](#), [Detail SD 15-12 CofWTSSM](#)]

**TECHNICAL STANDARDS – ADA:**

2. Handicap parking signs must be installed for the ADA spaces. Show the locations of the signs on the site plan.

Please let me know if you have any questions.