



**Planning, Development
and Transportation**

Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

DATE: 12.06.2018

TO: ProTrak

FROM: Mitesh Baxi
Traffic Engineering

■ **BLUEWATER MOTORSPORTS [TRC Plan Review #4]**

TECHNICAL STANDARDS – ACCESS (Sidewalk):

- Site plan shows a sidewalk connection between the site and the public sidewalk. Show the wheelchair ramp (with warning domes) at the location where this sidewalk connects an accessible aisle beside the accessible parking space. This is ensure that the sidewalk connection to the site is in accordance with ADA.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.