



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
www.wilmingtonnc.gov  
Dial 711 TTY/Voice

**DATE:** 12.16.2019

**TO:** ProTrak

**FROM:** Mitesh Baxi  
Traffic Engineering

---

■ **MCDONALD'S GORDON ROAD [TRC Plan Review #3]**

**TECHNICAL STANDARDS – ACCESS (crosswalk, sidewalk):**

1. Please show the existing pavement markings for the directional arrows for driveways off Market St and Gordon Rd.
2. The existing stop sign and stop bar at the driveway off Gordon Rd shall be relocated outside Gordon Rd ROW. Stop bar must be at least 4' in advance of a potential crosswalk at this driveway. [[Detail SD 3-09 CofW Tech Stds](#)]. Please revise accordingly.

Please let me know if you have any questions or if I can be of further assistance.