



**Planning, Development
and Transportation**
Transportation Planning
305 Chestnut Street
PO Box 1810
Wilmington, NC 28402-1810

DATE: 12.27.2018

TO: ProTrak

FROM: Mitesh Baxi
Traffic Engineering

910 341-3258
910 341-7801 fax
www.wilmingtonnc.gov
Dial 711 TTY/Voice

■ **AAA CAR WASH SOUTH COLLEGE ROAD [TRC Plan Review #4]**

TECHNICAL STANDARDS –PARKING:

1. Provide wheel stop for the parking space in the vicinity of vacuum equipment (labelled as 'L') to allow for 2.5' car overhang and avoid collision to any retaining wall or structure [[Sec.18-529 \(c\) \(2\) CofW LDC](#)].
2. Please confirm that detectable warning domes are installed at all the ADA ramps and at the surface entering drive aisle. It provides a distinctive texture intended to alert handicap person approaching vehicular areas [City/ADA standards].

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.