



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
www.wilmingtonnc.gov  
Dial 711 TTY/Voice

**DATE:** 12.28.2017  
**TO:** ProTrak  
**FROM:** Mitesh baxi  
Traffic Engineering

---

■ **INTRACOASTAL INTERNAL MEDICINE [TRC Plan Review #2]**

- Please show the location of the bicycle rack on the site plan and label it. Bicycle parking facilities shall be provided within two hundred (200) feet of the primary entrance to the facility. In the event of multiple entrances, bicycle-parking facilities shall be dispersed for easy access to the multiple entrances. [[Sec.18-528\(f\) CofW LDC](#)]
- No further comments.