



**Planning, Development  
and Transportation**

Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

910 341-3258  
910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
Dial 711 TTY/Voice

**DATE:** 01.29.2018

**TO:** ProTrak

**FROM:** Bill McDow  
Transportation Planning

---

■ **SMITH AND GSELL DESIGN STUDIO [TRC Plan Review #3]**

1. The site plans show a 3' sidewalk adjacent to the 6 standard vehicle parking spaces, however, the site appears to be allowing vehicle overhang over the sidewalk. Please increase the width of the sidewalk to allow 2.5' for vehicle overhang and 4' minimum clear pedestrian path for the sidewalk, or add wheel stops to prevent the vehicles from overhanging over the sidewalk.
2. No Further Comments.