

Engineering has reviewed the submittal for Schwartz Center Renovations and Additions from 06/23/2017 and has the following comments:

- Please add drainage plan approval stamps to all sheets (see attached).
- Site data table on sheet C-103 says the proposed building is 6,225 sf, while the stormwater permit application and sheet C-102 say it to be 3,952 sf. Please correct.
- The plans refer to the architectural plans for the sidewalk detail. Please include the architectural sheet that shows the sidewalk detail in the engineering submittal plan set.
- Provide additional spot elevations along sidewalks to demonstrate ADA compliance and constructability.
- Correct the project address on both the stormwater permit application and the plans. It should be 610 N Front St.
- Provide a project boundary so that Section IV Project Information #1 - #13 can be completed on the stormwater permit application. Project boundary can contain a large enough area to encompass area needed to complete the project. Total property area is not necessary.