

**From:** [Rob Gordon](#)  
**To:** [Phil Tripp \(ptripp@trippengineering.com\)](mailto:ptripp@trippengineering.com)  
**Cc:** [Tripp Engineering \(trippeng@ec.rr.com\)](mailto:trippeng@ec.rr.com); [Trent Butler](#); [Brian Chambers](#)  
**Subject:** Eng Review - the Homeplace  
**Date:** Monday, July 31, 2017 5:03:33 PM  
**Attachments:** [image003.png](#)

---

Engineering has reviewed the submittal for the Homeplace project and have the following comments:

1. The sidewalk around the cul-de-sac was removed but the impervious totals remained unchanged. You can add the difference to the future allocation or distribute to the lots to avoid changing overall BUA.
2. The DA is listed as 9.45 ac on the DA map and 11.91 ac in the calcs and application. Unfortunately, the DA map appears correct because the pond DA does not include the entire parcel area. This would require resubmittal of calcs and application.
3. As long as you are having to resubmit calcs – please update the pipe calcs to include (new) DI2. Please also make sure the inlet DA map includes DI2.

Please submit a final set of sealed calcs and DA maps. Please also make any corresponding changes to the plans and forms to avoid additional project delays. I will make every attempt to review the final submittal quickly. Please call or email if there are any questions. Thank you.

Robert Gordon, PE  
Plan Review Engineer

City of Wilmington, Engineering Division  
212 Operations Center Drive  
Wilmington, NC 28412  
Office: (910) 341-5856 | Fax: (910) 341-5881  
Email: [rob.gordon@wilmingtonnc.gov](mailto:rob.gordon@wilmingtonnc.gov)  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)



**Follow us on Facebook or Twitter**

[facebook/cityofwilmington](https://www.facebook.com/cityofwilmington)  
[@cityofwilm](https://twitter.com/cityofwilm)