

Engineering has reviewed the plans for the NHRMC Wound Care Parking Lot project submitted 08/31/2017 and has the following comments:

1. On sheet C3, pull the gate valve and the water meter off of the existing sidewalk.
2. To reiterate transportation planning, submit the variance request for the 230' minimum corner clearance along major thoroughfares.