

Engineering has reviewed the November 9, 2017 submittal for the Tongue & Groove Office project and has the following comments:

- The plans appear to show an open slatted handicap ramp. Please specify as “open slatted” on the plan callout. If it is to be concrete, add it to the impervious calculation if it is not included already.
- Fill out Sect IV #7 for existing impervious to be removed.
- Replace the stormwater management plan stamp with a drainage plan approval stamp on the landscape sheet.
- These items can be checked for at final signature instead of an additional submittal.