

Engineering has reviewed the TRC submittal for the Custom Home Furniture project and has the following comments:

- This project has between 2,500 and 10,000 sf of onsite newly constructed impervious. Therefore, it qualifies as a drain plan. Please submit a set of revised plans, stormwater management permit application form (Form SWP 2.2), and a check for \$200.00 for drainage plan review fee.
- Include the City of Wilmington drainage plan approval stamp on all sheets.