

Engineering has reviewed the January 30, 2018 submittal for the Custom Home Furniture project and offers the following comments:

- The project proposes less than 2,500 sf of newly constructed impervious which qualifies it as a “no permit required” plan.
- Replace drainage plan stamps with “no permit required” stamps on all sheets.
- Engineering has no further comments.