

Engineering has reviewed the February 09, 2018 submittal for the Intracoastal Internal Medicine project and offers the following comments:

- Revise the legend on sheet C-2. It denotes a 3:1 grassed swale when it should be 5:1.
- Engineering has no further comments.