

Engineering has reviewed the 03/29/2018 submittal for the Corning Credit Union project and offers the following comments:

Calculations:

1. Please use the SCS Method for pre-post stormwater calculations. Pre-post calculations are only required for the 10-year storm.

Plans:

1. Two tactile warning mats will be required at the ADA ramp at the intersection of Federal Park Dr and the unnamed private drive (see markup).
2. ADA ramps on 17th St cannot be retro-fitted, they will have to be completely replaced and include cast-in-place red warning mats. Please add a callout that calls for coordination of construction with city ROW inspector.
3. Show concrete removed and replaced for the ADA ramps on 17th St.
4. Extend limits of disturbance to include ADA ramps on 17th St.
5. Show sidewalks continuing through all driveways (see markup).

SW Permit Application:

1. Revise offsite impervious totals to include ADA ramps on 17th St.

The next submittal can be sent digitally since there are very few comments.