

Engineering has reviewed the plans for the Hurst Hamilton Parking Lots project submitted May 23, 2018 for TRC review and have the following comments:

1. This project is proposing the construction of on-site newly constructed impervious surface greater than 10,000 sf, therefore the project is subject to stormwater review. An Engineering submittal was received on May 24, 2018. The project will be reviewed for grading, drainage and compliance with City technical standards only. Please submit the Stormwater Management Permit Application Form and a \$1,000 permit application processing fee. Additional comments will be made once the full engineering submittal is reviewed. Please note our review times are approximately 45-60 days right now. Please factor this into your submittal schedule.

Please call or email if there are any questions. Thank you.