

Engineering has reviewed the June 14, 2018 submittal for the Conway Peiffer Avenue Subdivision project and offers the following comments:

Plans:

1. Provide stormwater calculations for the swale and the infiltration basin. Because the site drains across neighboring properties without a suitable outfall, show that the swale and infiltration basin can hold the 2, 10, 25 year storm at a minimum.
2. Extend the swale to the east to capture more of the generated runoff.