

Engineering has reviewed the July 25, 2018 submittal for the Calibration Station Offices project and offers the following comments:

Plans:

1. Provide spot elevations along the proposed sidewalks to demonstrate ADA compliance and constructability.
2. On sheet C2.1, replace the stormwater management approval stamp with the drainage plan approval stamp.
3. Engineering and Construction Management request that the ramps at the corner of Burnett Blvd and Southern Blvd be combined into one ramp.
4. Provide spot elevations at the proposed gutter line and existing pavement at the corner of Burnett Blvd and Southern Blvd in order to ensure positive drainage to the existing curb inlet is achieved. A portion of the pavement may need to be reworked in order to prevent water from ponding directly in front of the ramp.
5. On the stormwater permit application, Section IV #10 should be existing impervious to remain plus newly constructed impervious ($980\text{sf} + 7428\text{sf} = 8408\text{sf}$). Please revise Section IV #10 & #11.
6. On the stormwater permit application, fill out Section IV # 12 and revise #13. Section IV # 12 should include all off-site newly constructed impervious (sidewalks, ramps, driveways, etc.).