

Engineering has reviewed the October 4, 2018 submittal for the Saltwater Properties, LLC project and has the following comments:

1. Please replace the stormwater management plan stamp with the City of Wilmington drainage plan approval stamp on all sheets.
2. Provide a timber barrier around the landscape area to the south of the ADA parking space. Make it clear on the plans that all landscape areas are to be bordered with a 6" barrier.
3. Add multiple spot elevations to the proposed driveway throat and flare tie-in.
4. Add spot elevations to the proposed sidewalk in the ROW to demonstrate ADA compliance and constructability.
5. Provide a section detail for the proposed washed stone parking.