

From: [Trent Butler](#)
To: [cmatthews \(cmatthews@paramounte-eng.com\)](mailto:cmatthews@paramounte-eng.com)
Cc: [Brian Chambers](#); [Richard Christensen](#); [Rob Gordon](#); [Eric A. Seidel \(Eric.Seidel@wilmingtonnc.gov\)](mailto:Eric.Seidel@wilmingtonnc.gov)
Subject: Eng Review - Calibration Station Offices
Date: Thursday, November 15, 2018 10:03:00 AM
Attachments: [image001.png](#)

Engineering has reviewed the 11/07/2018 submittal for the Calibration Station Offices project and offers the following comments.

1. Add a callout to direct roof drains to proposed parking lots.
2. No further comments.

Trent Butler

Staff Engineer

City of Wilmington, Engineering Division

P. O. Box 1810 | 212 Operations Center Dr.

Wilmington, NC 28402-1810

910.341.0094 | Fax 910.341.5881

trent.butler@wilmingtonnc.gov

www.wilmingtonnc.gov



Follow us on Facebook or Twitter

[facebook/cityofwilmington](https://www.facebook.com/cityofwilmington)

[@cityofwilm](https://twitter.com/cityofwilm)