

Engineering has reviewed the TRC submittal for the McDonald's Remodel project and offers the following comments:

1. The project proposes less than or equal to 2,500 square feet of newly constructed impervious, qualifying it as "no permit required".
2. Please contact NCDEQ to determine if this project requires a revision to a state stormwater permit.
3. On the impervious data table on sheet C-5, list the impervious areas in square feet. Also list the amount of on-site newly constructed impervious.