

Engineering has reviewed the plans for CFPUA Pump Station #10 Replacement project submitted to TRC January 16, 2019 and have the following comments:

**Note: A formal Engineering submittal package was accepted on January, 23<sup>rd</sup> 2019 with the following comments a result of a Full Drainage Plan Review.**

**Stormwater Management Permit Application Form:**

- 1) IV. Project Information; Line item 12: Include required public sidewalk improvements as impervious sidewalk and update Line Item 13 accordingly.

**Plans:**

- 2) Demo Plan (01X-01): Identify in General Notes & Construction Sequence that contractor is to dispose of Demoed Asphalt, C&G, Concrete, Buildings, and Fencing at a certified offsite disposal facility.
- 3) Site Plan (01C-01): Site Information Table; please breakdown impervious surface in a manner consistent with application to show project is under 10,000 sf Newly Constructed Impervious surface threshold.
- 4) Please provide City Standard Sidewalk along property frontage per section 18-376 of Wilmington Code.

Please submit revised plan sheets, application page, and any other documentation to Engineering for additional review. Please call or email if there are any questions.