

Engineering has reviewed the plans for the Wilmington Treatment Center PHC and Dorms project submitted October 9, 2019 for TRC review and have the following comments:

1. The project is proposing in excess of 10,000 sf of on-site newly constructed impervious surface area and will be subject to full stormwater review. The existing City SW Permit (2017032R2) will need to be modified. Please submit the \$400 Minor Modification Review Fee. A complete set of design plans, calculations and SW Application were submitted as part of the TRC submittal. Please send a digital copy of that submittal to Engineering for our records.
2. Please submit the original and one copy of the SW Application.
3. SW Application:
 - a. Delete the Drainage Plan 'X' on page 1.
 - b. Update the current SW permit number to 2017032**R2** on page 1.
 - c. The 'Total Onsite Newly Constructed Impervious Surface' square footage on page 3 (#9) should be 185,215, not 190,513.
 - d. The 'Total Newly Constructed Impervious Surface' square footage on page 4 (#13) should be 186,843, not 192,141.
4. All plan sheets need to have the Engineering Approval Stamp.
5. Omit the CFPUA detail sheets.

Please call or email if there are any questions. Thank you.