

Engineering has reviewed the plans for The Lofts at Park Avenue project submitted October 21, 2019 and have the following comments:

Stormwater Management Permit Application Form:

- 1) IV. Project Information, Line Item 12 & 13: Include 10' Multi-Use Path for Newly Offsite Constructed Impervious Surface.

Plans:

- 2) SP-01: The construction of 10' Multi-Use Path will be required for this project. Note: Payment in-lieu will not be accepted. Please provide design (with spot elevations) showing path will meet ADA compliant cross and longitudinal slopes. Please also show path is in compliance with horizontal and/or vertical clear zone requirements.

Please submit revised plan sheets, revised application page, and any other documentation to Engineering for additional review. Please call or email if there are any questions. Thank you.